

M8 male recept. A-cod. front

PP-wires 3x0.25 1m


Flange male M8, 3-pole Front mounting with multi-strand wire


Link to Product

Illustration









Product may differ from Image



Cable length	1 m
Side 1	
Tightening torque	0,4 Nm
Mounting method	inserted, screwed
Family construction form	M8

The information in this Product-PDF has been compiled with the utmost care. Liability for the correctness completeness and topicality of the information is restricted to gross negligence. Version: 2024-05-17



stay connected

Thread	M8 x 1
Material	Brass
Degree of protection (EN IEC 60529)	IP67
Commercial data	
ECLASS-6.0	27279220
ECLASS-6.1	27279220
ECLASS-7.0	27440103
ECLASS-8.0	27440103
ECLASS-9.0	27440103
ECLASS-10.1	27440103
ECLASS-11.1	27440103
ECLASS-12.0	27440103
ETIM-5.0	EC001855
customs tariff number	85444290
GTIN	4048879435154
Packaging unit	1
	'
Electrical data Supply	
Operating voltage AC max.	50 V
Operating voltage DC max.	60 V
Current operating per contact max.	4 A
Installation Connection	
Mounting set	M8 x 1
Device protection Electrical	
Additional condition protection degree	inserted, screwed
Rated surge voltage	1,5 kV
Mechanical data Material data	.,
· · · · · · · · · · · · · · · · · · ·	
Coating of fitting	nickel plated
Material screw connection	Brass
Mechanical data Mounting data	
Mounting method	Schraubgewinde
Looking techniques	Schraubgewinde
Environmental characteristics Climatic	
Operating temperature min.	-25 °C
Operating temperature max.	85 °C
Additional condition temperature range	depending on cable quality
	depending on cable quality
Important installation notes	
Important installation notes	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties.
Important installation notes Note on strain relief	
Important installation notes Note on strain relief Note on bending radius	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be
Important installation notes Note on strain relief Note on bending radius Installation Cable	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.
Important installation notes Note on strain relief Note on bending radius Installation Cable Cable identification	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces.
Important installation notes Note on strain relief Note on bending radius Installation Cable Cable identification wire arrangement	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. 970 brown, black, blue
Important installation notes Note on strain relief Note on bending radius Installation Cable Cable identification wire arrangement Material wire insulation	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. 970 brown, black, blue PP
Important installation notes Note on strain relief Note on bending radius Installation Cable Cable identification wire arrangement Material wire insulation Amount wires	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. 970 brown, black, blue PP 3
Important installation notes Note on strain relief Note on bending radius Installation Cable Cable identification wire arrangement Material wire insulation Amount wires Outer diameter insulation	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. 970 brown, black, blue PP 3 1,1 mm
Important installation notes Note on strain relief Note on bending radius Installation Cable Cable identification wire arrangement Material wire insulation Amount wires Outer diameter insulation Outer diameter tolerance core insulation	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. 970 brown, black, blue PP 3 1,1 mm ± 5 %
Important installation notes Note on strain relief Note on bending radius Installation Cable Cable identification wire arrangement Material wire insulation Amount wires Outer diameter insulation Outer diameter tolerance core insulation Conductor crosssection (wire)	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. 970 brown, black, blue PP 3 1,1 mm ± 5 % 0,25 mm²
Important installation notes Note on strain relief Note on bending radius Installation Cable Cable identification wire arrangement Material wire insulation Amount wires Outer diameter insulation Outer diameter tolerance core insulation Conductor crosssection (wire) Min. operating temperature (static)	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. 970 brown, black, blue PP 3 1,1 mm ± 5 % 0,25 mm² -40 °C
Additional condition temperature range Important installation notes Note on strain relief Note on bending radius Installation Cable Cable identification wire arrangement Material wire insulation Amount wires Outer diameter insulation Outer diameter tolerance core insulation Conductor crosssection (wire) Min. operating temperature (static) Max. operating temperature (fixed) Operating temperature min. (dynamic)	Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. Attention: Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. 970 brown, black, blue PP 3 1,1 mm ± 5 % 0,25 mm²



Flame resistance	UL 1581 § 1090 UL 1581 § 1100 FT2 IEC 60332-2-2
chemical resistance	Good, application-related testing
Gasoline resistance	Good, application-related testing
Oil resistance	DIN EN 60811-404 Good, application-related testing
Bending radius (fixed)	5 x Outer diameter